



IMPORTANT

Remove jumper between terminal I & C before connecting interlocks.
 Wire in accordance with local & Canadian Electrical codes. Read carefully installations before wiring and operating.

Frame shown in heavy line represents Thermolec Electric Coil. All wiring outside this frame are "typical external wiring by others".

LEGEND

- A Automatic Reset Cut Out
- C1,C2 Operating Contactors
- CM Back-up Contactor to manual cut-out
- D46 Electronic Step Controller
- F Fuse
- PDS Pressure Differential Switch
- R Relay
- SSR Solid State Relay
- T Control Circuit Transformer
- TH Thermostat
- DT Duct Thermostat
- DISC Disconnect Switch

TITLE/TITRE



THERMOLEC

MONTREAL - CANADA

LTEE
LTD

DRAWING NO. 2B56-7M2U-6500-0000

DATE

PER